

**Annexure D**

**BUILDING SAFETY CERTIFICATE**

No.

Dated: 30/01/2025


It is certified that the existing building **Shriram Academy** (name of the Building or premises) at Gut No.78/3 **Bhairavnathnagar, Gondhavani, Tal-Shrirampur, Dist – Ahilyanagar, State - Maharashtra**(address) is having block(s)/Floor(s) as per details below:

Detail of Blocks(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floors(s) in the Block	1					

The building is owned/occupied by **Shrirampur Education Society** (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of **P.W.Sub-division Shrirampur** (Name of Department/ Govt.) on 30/01/2025 (date of inspection) in the presence of **Mrs. Jayashri Arun Potghan** (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 30/01/2025 for a period of 1 years in accordance with rule and subject to compliance of the specific conditions as appended.

- 1.This considers that execution was done by the institute strictly as per designs and relevant code provisions.
- 2.If any differences in designs and relevant code provisions this certificate was automatically cancelled.
- 3.Cracks are observed in Wall,beam and column junctions, Instructions given to rectify this.If not rectify this certificate will automatically cancelled.
- 4.This certificate is being issued in accordance with the reference letter date 25/01/2025 given by Mr. Chetan M. Bhutada.

Issued on 30/01/2025 at Shrirampur by Sub Divisional Officer Public Works sub Division, Shrirampur.

  
**Sub-Divisional Officer,**  
**P.W.Sub-Division,**  
**Shrirampur.**